FIRE EXTINGUISHERS IN FACILITIES



The JBER Fire & Emergecncy Services Flight is the authority for all matters involving fire extinguishers on IBER per AFMAN 91-203.

References: NFPA 10 NFPA 96 NFPA 101 UFC 3-600-01 DESR 6055.09-AFMAN 91-201 AFMAN 91-203

Look for us on Facebook JBER Fire Prevention



Fire Prevention Office 724 Quartermaster Rd (NE Corner, 2nd Floor)

Phone: 907-384-5555 Fax: 907-384-3212

673ces.cef.fireprevention@us.af.mil

Classes of Extinguishers:





cloth

• wood

rubber

paper







metals





"The combined results of the 34 years of data... of the 13,221 fire incidents reported [involving fire extinguisher use], portable fire extinguishers successfully extinquished 12,505 fires (95%)" - National Association of Fire Equipment Distributors, 2010

The National Defense Authorization Act For Fiscal Year 2020 removed the fire extinguisher exemption for DoD buildings with fire suppression systems. Fire extinguishers must be maintained and located in accordance with NFPA requirements regardless of facility fire suppression systems.

Guidance for required extinguishers is provided on page 2

TRAINING:

OSHA 1910.157(g) requires initial and annual training for employees where portable fire extinguishers are provided for employee use in the workplace. Training does not always require hands on experience and can be as simple as reviewing an approved fire extinguisher demonstration, slide show, computer course, or movie. Hands on training is available from the JBER Fire Prevention Office upon request and specialized training may be required for specific operations such as commercial cooking.

DISPOSAL OF UNSERVICEABLE FIRE EXTINGUISHERS:

There is a drop box for unserviceable fire extinguishers located at the northeast corner of building 724. Keep in mind that many extinguishers can be serviced by a local vendor and it may be cheaper than buying a new one. Contact the JBER Fire Prevention Office if you have questions.

JBER FIRE & EMERGENCY SERVICES

MAINTENANCE:

General purpose ABC dry chemical fire extinguishers require 6-year maintenance and 12-year hydrostatic testing. Other extinguisher types may have different maintenance cycles.

MOVING OR CHANGING TYPE/SIZE OF A FIRE EXTINGUISHER:

Do not remove, relocate, or replace with a different type/size fire extinguisher unless approved by the Fire Prevention Office.

Specific Areas Requiring Specific Fire Extinguishers	Class of Extinguisher	Maximum Travel Distance (ft)
Arms Rooms (Needs two, one inside and one outside)	ABC	30 (Outside of Arms Room Door)
Commercial Cooking Areas	K	30
Flammable Storage	BC	30 - 50 (depends on extinguisher size)
General Purpose (i.e. located throughout the occupancy)	ABC	75 (from any location)

Occupancy	General Purpose Extinguishers Required	Areas Having Additional Fire Extinguisher Requirements *Contact the JBER Fire Prevention Office for further guidance	
Assembly	NO	- Kitchens - Flammable Storage - Food warming areas	
Business / Mercantile	YES	- Training systems (cockpit/vehicle/computer bay/display rooms) - Wheeled egress trainers - Areas not evacuated - Flammable storage - Arms Rooms/Ammo Storage	
Commercial Cooking Spaces	YES	- Kitchens - Flammable Storage	
Day-Care	NO	- Kitchens - Flammable Storage	
Detention and Correctional	YES	- Kitchens - Arms Rooms/Ammo Storage - Flammable Storage	
Dormitory / Barracks / Lodging	NO	- Arms Rooms - Flammable Storage - Laundries > 100 ft ² - Trash Collection Rooms - Maintenance Areas	
Educational (K-12)	NO	- Kitchens - Flammable Storage	
Electronic Spaces	YES	- High-value/critical substation/motor control equip use FE-36 - Information technology - use carbon dioxide (min. 2-A rated)	
Health Care	YES	- Kitchens - Laboratories - Flammable Storage	
Industrial	NO	 Flammable storage areas Welding areas Paint spraying/booths Battery shops/rooms Multimedia laboratories Explosives handling CE shop areas Laboratories Soldering areas Dip tanks Laundries/Dry Cleaners Arms Rooms/Ammo Storage 	
Storage	NO	- Flammable storage - Arms Rooms/Ammo Storage - Explosives Handling - Material Handling Equipment w/internal combustion engine	

This document was established as a quick reference guide and is not all inclusive. Please contact the Fire Prevention Office for assistance in determining your fire extinguisher requirements.